



United Fire Systems

A Complete Fire Solution
Government licence Holder

Service@unitedfiresystems.in www.unitedfiresystems.in

Manufacturers, Suppliers & Services

● Fire Extinguishers ● Fire Hydrants & Sprinklers ● Fire Suppression Systems ● Fire Alarm Systems ● Annual Maintenance Services

Report of Hydrostatic Stretch-Test of ABC-DRY CHEMICAL (MAP 50%) STORED PRESSURE TYPE FIRE EXTINGUISHERS

Certificate no – UFS-TC/32-2023

Date –29.11.2023

HPT Date – 29.11.2023

Next Due Date – 28.11.2024

Name of the party – Navyug English Medium School ,
Ladvali Tal.-Mahad, Dist.-Raigad Maharashtra.

INSPECTION REPORT

No. of Extinguishers	18 Nos.
Type of Extinguishers	ABC (MAP50%) DRY CHEMICAL POWDER STORED PRESSURE TYPE FIRE EXTINGUISHERS AS PER IS:2190:2010
Visual inspection – Internal & External	SATISFACTORY
Test Pressure	35 Kgs/cm ²
Duration of Test Pressure	2.5 Minutes
Name of the chemical to be filled	ABC -MAP- MONO AMONIUM PHOSPHET POWDER WITH ISI MARKED (KV LITE) IS:4308:2006
Panting/Re-Labeling/ Numbering	Yes/Yes/Yes
Extinguishers Serial No.	SR.NO. – ABC 01 Kg (03 Nos.) ABC 02 Kg (01 Nos.) ABC 06 Kg (14 Nos.)
Specification & Result	Satisfactory

AUTHORISED SIGNATORY



FOR UNITED FIRE SYSTEMS